

1 DESCRIPTION AND JUSTIFICATION FOR ENERGIZED ELECTRICAL WORK

Hazard / Risk Category (circle category number)	-1 0 1 2 3 4
---	---------------------------------------

2 EQUIPMENT INFORMATION

Name of Equipment	Description of circuit
Identification	
Location	
Power fed from	
Drawing Number	

3 FLASH HAZARD ANALYSIS

FLASH HAZARD ANALYSIS (from NFPA-70E, 130.3 (A))

Fault Clearing Device: (name): _____ (description) _____
Mfg'r's Model or type number: _____
Clearing time, seconds: _____

Flash Protection Boundary
(Check the method used)
 4.0 feet (systems less than 600 volts, with 0.1-sec clearing time, Ibf < 50 kA, or 5000 A-sec)
 Physical boundaries of the substation or enclosure (systems greater than 600 volts)
 Other (Contact the Electrical Shop for assistance)

BARRIERS to restrict access by unqualified persons:

<input type="checkbox"/> Locked access	<input type="checkbox"/> Safety Watch Required
<input type="checkbox"/> Barrier tapes, stanchions	
<input type="checkbox"/> Electrical Hazard signs	<input type="checkbox"/> Other (describe task): _____

4 SHOCK HAZARD ANALYSIS (VOLTAGE, BOUNDARIES, PPE)

ELECTRICAL ENERGY SOURCE HAZARDS FOR THIS PERMIT (Check all that apply)

<input type="checkbox"/> Less than 50 volts,	<input type="checkbox"/> 277 volts	<input type="checkbox"/> Emergency power _____
<input type="checkbox"/> 120-volts	<input type="checkbox"/> 480 volts	<input type="checkbox"/> Remote control _____
<input type="checkbox"/> 208 volts	<input type="checkbox"/> 600 volts	<input type="checkbox"/> DC _____
<input type="checkbox"/> 240 volts	<input type="checkbox"/> Other (describe): _____	<input type="checkbox"/> Foreign _____

SHOCK PROTECTION - APPROACH BOUNDARIES TO LIVE PARTS

Multiply single-phase voltages by 1.73 to obtain correct voltage level to be used (NFPA 70E C.2.11)

SYSTEM VOLTAGE:	LIMITED APPROACH* DISTANCE	RESTRICTED APPROACH DISTANCE	PROHIBITED APPROACH DISTANCE
<input type="checkbox"/> less than 50 volts	<input type="checkbox"/> Not spec'd	<input type="checkbox"/> Not spec'd	<input type="checkbox"/> Not spec'd
<input type="checkbox"/> 50 to 300 volts	<input type="checkbox"/> 4' 0" ¹	<input type="checkbox"/> avoid contact	<input type="checkbox"/> avoid contact
<input type="checkbox"/> 301 to 750	<input type="checkbox"/> 4' 0" ¹	<input type="checkbox"/> 1' 0"	<input type="checkbox"/> 0' 1"
<input type="checkbox"/> 751 to 15kV	<input type="checkbox"/> 5' 0" ²	<input type="checkbox"/> 2' 2"	<input type="checkbox"/> 0' 7"
<input type="checkbox"/> 15.1 kV to 36 kV	<input type="checkbox"/> 6' 0" ²	<input type="checkbox"/> 2' 7"	<input type="checkbox"/> 0' 10"

* If any conductors moveable, limited approach distance is 10 feet.

1 Limited Approach is equal to the flash protection boundary

2 Limited Approach is equal to the physical limits of the equipment room. Limited Approach for open areas is the distance listed or the Flash Protection Boundary, whichever is the greatest

5 Protective Clothing and Equipment

Circle all of the equipment that will be used for the work

Protective Systems for Hazard / Risk Category	Hazard / Risk Category Number					
	-1	0	1	2	3	4
Non-Melting or Untreated Natural Fiber						
T-shirt (short sleeve)	X			X	X	X
Shirt (long sleeve)		X				
Pants (long)	X	X	X	X	X	X
			Note 4	Note 6		
FR Clothing (see note 1)						
Long-sleeved shirt			X	X	X	X
Pants			X	X	X	X
Coverall			Note 5	Note 7	X	Note 5
Jacket, Parka, or raingear			AN	AN	AN	AN
FR Protective Equipment						
Flash suit jacket (multilayer)						X
Flash suit pants (multilayer)						X
Head Protection						
Hard Hat			X	X	X	X
FR Hard Hat liner						
					AR	AR
Eye Protection						
Safety Glasses	X	X	X	AL	AL	AL
Safety Goggles				AL	AL	AL
Face and Head Area Protection						
Arc-rated face shield, or flash suit hood				X		
Flash suit Hood					X	X
Hearing protection (ear canal inserts)				X	X	X
				Note 8		
Hand Protection Leather Gloves			AN	X	X	X
Foot Protection Leather Work Shoes			AN	X	X	X

AN = as needed, AL = Select one in group, AR = as required, X= minimum required

6 APPROVALS /AGREEMENTS TO PERFORM WORK WHILE ELECTRICALLY ENERGIZED

Engineering Services

Director

Assistant Director (Electrical)

Electric Shop

Supervisor

Lead

Electrically Qualified Person(s)

Electrically Qualified Person(s)

Electrically Qualified Person(s)

Electrically Qualified Person(s)